

## 5. March 2024 Chemical Dose

Location, Chemical	Dose	Consumption
PST, Ferric Chloride	13.7 mg/l	4,721 gal
PST, Anionic Polymer	0.00 mg/l	0.0 gal
Belt Press, Cationic Polymer	7.8 lbs/ton	29,778 gal
Belt Press, Lime	0 lbs/ton	0 tons
Odor Control, Sodium Hypochlorite	>575 mv	11,280 gal
Odor Control, Sodium Hydroxide	>9.0 pH	896 gal
Odor Control, Sulfuric Acid	<4.0 pH	27 gal
Reclaim Water Chlorine	0.0 mg/l	0 gal

## 6. March 2024 Solids Quantity

Disposal Material	No. of Trucks	Weight, Tons	Average No. of Trucks per Day
Grit/Screening Hauling	6	144.3	0.19
Solids Hauling	128	3,134.5	4.13

## 7. February 2024 Solids Quality

Sludge Solids	pH	Raw Sludge, % Solids	Unstabilized Sludge, % Solids	Stabilized Sludge, % Solids
Monthly Minimum	6.6	0.7	15.7	15.6
Monthly Maximum	7.3	3.4	20.7	21.8
Monthly Average	7.0	1.8	18.6	18.6

## 8. March Non Potable Water Usage

NPW Monthly Average, gal.	NPW Min, gal.	NPW Max, gal.	NPW 6-month Moving Average, gal.
1,808,000	1,297,000	2,161,000	1,941,653

## 5. April 2024 Chemical Dose

Location, Chemical	Dose	Consumption
PST, Ferric Chloride	15.3 mg/l	5,872 gal
PST, Anionic Polymer	0.00 mg/l	0.0 gal
Belt Press, Cationic Polymer	32.78 lbs/ton	21,234 gal
Belt Press, Lime	0 lbs/ton	0 tons
Odor Control, Sodium Hypochlorite	>575 mv	10,753 gal
Odor Control, Sodium Hydroxide	>9.0 pH	1,131 gal
Odor Control, Sulfuric Acid	<4.0 pH	50 gal
Reclaim Water Chlorine	0.0 mg/l	0 gal

## 6. April 2024 Solids Quantity

Disposal Material	No. of Trucks	Weight, Tons	Average No. of Trucks per Day
Grit/Screening Hauling	37	1,472.2	1.23
Solids Hauling	115	2,799.5	3.83

## 7. March 2024 Solids Quality

Sludge Solids	pH	Raw Sludge, % Solids	Unstabilized Sludge, % Solids	Stabilized Sludge, % Solids
Monthly Minimum	6.3	0.6	16.0	16.4
Monthly Maximum	7.4	4.8	21.9	21.8
Monthly Average	6.9	3.0	19.2	19.1

## 8. April Non Potable Water Usage

<b>NPW Monthly Average, gal.</b>	<b>NPW Min, gal.</b>	<b>NPW Max, gal.</b>	<b>NPW 6-month Moving Average, gal.</b>
1,957,867	1,404,000	2,828,000	1,873,839

---

## 5. May 2024 Chemical Dose

Location, Chemical	Dose	Consumption
PST, Ferric Chloride	5.8 mg/l	8,290 gal
PST, Anionic Polymer	0.00 mg/l	0.0 gal
Belt Press, Cationic Polymer	14.50 lbs/ton	30,988 gal
Belt Press, Lime	0 lbs/ton	0 tons
Odor Control, Sodium Hypochlorite	>575 mv	15,415 gal
Odor Control, Sodium Hydroxide	>9.0 pH	1,205 gal
Odor Control, Sulfuric Acid	<4.0 pH	61 gal
Reclaim Water Chlorine	0.0 mg/l	0 gal

## 6. May 2024 Solids Quantity

Disposal Material	No. of Trucks	Weight, Tons	Average No. of Trucks per Day
Grit/Screening Hauling	36	1,343.3	1.16
Solids Hauling	156	3,858.9	5.03

## 7. April 2024 Solids Quality

Sludge Solids	pH	Raw Sludge, % Solids	Unstabilized Sludge, % Solids	Stabilized Sludge, % Solids
Monthly Minimum	6.1	3.0	16.3	16.3
Monthly Maximum	6.8	4.0	25.6	26.7
Monthly Average	6.5	3.7	22.4	22.6

---

## 5. June 2024 Chemical Dose

Location, Chemical	Dose	Consumption
PST, Ferric Chloride	8.0 mg/l	8,290 gal
PST, Anionic Polymer	0.00 mg/l	0.0 gal
Belt Press, Cationic Polymer	19.12 lbs/ton	27,046 gal
Belt Press, Lime	0 lbs/ton	0 tons
Odor Control, Sodium Hypochlorite	>575 mv	11,205 gal
Odor Control, Sodium Hydroxide	>9.0 pH	999 gal
Odor Control, Sulfuric Acid	<4.0 pH	69 gal
Reclaim Water Chlorine	0.0 mg/l	0 gal

## 6. June 2024 Solids Quantity

<b>Disposal Material</b>	<b>No. of Trucks</b>	<b>Weight, Tons</b>	<b>Average No. of Trucks per Day</b>
Grit/Screening Hauling	26	820.5	0.87
Solids Hauling	145	3,667.5	4.83

## 7. May 2024 Solids Quality

<b>Sludge Solids</b>	<b>pH</b>	<b>Raw Sludge, % Solids</b>	<b>Unstabilized Sludge, % Solids</b>	<b>Stabilized Sludge, % Solids</b>
Monthly Minimum	6.3	2.9	16.7	18.2
Monthly Maximum	6.9	3.5	24.9	25.0
Monthly Average	6.6	3.2	21.4	21.7

## 8. June 2024 Non Potable Water Usage

<b>NPW Monthly Average, gal.</b>	<b>NPW Min, gal.</b>	<b>NPW Max, gal.</b>	<b>NPW 6-month Moving Average, gal.</b>
2,328,300	1,683,000	2,904,000	1,830,196

## 5. July 2024 Chemical Dose

Location, Chemical	Dose	Consumption
PST, Ferric Chloride	6.8 mg/l	15,775 gal
PST, Anionic Polymer	0.00 mg/l	0.0 gal
Belt Press, Cationic Polymer	17.80 lbs/ton	21,911 gal
Belt Press, Lime	0 lbs/ton	0 tons
Odor Control, Sodium Hypochlorite	>575 mv	10,810 gal
Odor Control, Sodium Hydroxide	>9.0 pH	1,293 gal
Odor Control, Sulfuric Acid	<4.0 pH	46 gal
Reclaim Water Chlorine	0.0 mg/l	0 gal

## 6. July 2024 Solids Quantity

<b>Disposal Material</b>	<b>No. of Trucks</b>	<b>Weight, Tons</b>	<b>Average No. of Trucks per Day</b>
Grit/Screening Hauling	57	1,471.5	1.84
Solids Hauling	110	2,671.9	3.55

## 7. June 2024 Solids Quality

<b>Sludge Solids</b>	<b>pH</b>	<b>Raw Sludge, % Solids</b>	<b>Unstabilized Sludge, % Solids</b>	<b>Stabilized Sludge, % Solids</b>
Monthly Minimum	6.7	2.9	15.4	15.2
Monthly Maximum	7.0	4.0	24.9	25.1
Monthly Average	6.9	3.6	18.9	18.7

## 8. July Non Potable Water Usage

<b>NPW Monthly Average, gal.</b>	<b>NPW Min, gal.</b>	<b>NPW Max, gal.</b>	<b>NPW 6-month Moving Average, gal.</b>
2,594,387	1,853,000	3,270,000	1,915,588



## 5. August 2024 Chemical Dose

Location, Chemical	Dose	Consumption
PST, Ferric Chloride	14.1 mg/l	11,284 gal
PST, Anionic Polymer	0.00 mg/l	0.0 gal
Belt Press, Cationic Polymer	11.44 lbs/ton	36,927 gal
Belt Press, Lime	0 lbs/ton	0 tons
Odor Control, Sodium Hypochlorite	>575 mv	9,813 gal
Odor Control, Sodium Hydroxide	>9.0 pH	676 gal
Odor Control, Sulfuric Acid	<4.0 pH	46 gal
Reclaim Water Chlorine	0.0 mg/l	0 gal

## 6. August 2024 Solids Quantity

<b>Disposal Material</b>	<b>No. of Trucks</b>	<b>Weight, Tons</b>	<b>Average No. of Trucks per Day</b>
Grit/Screening Hauling	25	789.5	0.81
Solids Hauling	161	3,900.4	5.19

## 7. July 2024 Solids Quality

<b>Sludge Solids</b>	<b>pH</b>	<b>Raw Sludge, % Solids</b>	<b>Unstabilized Sludge, % Solids</b>	<b>Stabilized Sludge, % Solids</b>
Monthly Minimum	6.7	1.8	14.3	15.1
Monthly Maximum	6.9	4.3	23.8	23.9
Monthly Average	6.8	2.9	19.2	19.9

## 8. August Non Potable Water Usage

<b>NPW Monthly Average, gal.</b>	<b>NPW Min, gal.</b>	<b>NPW Max, gal.</b>	<b>NPW 6-month Moving Average, gal.</b>
2,439,903	1,739,000	2,900,000	2,032,220

## 5. September 2024 Chemical Dose

Location, Chemical	Dose	Consumption
PST, Ferric Chloride	17.5 mg/l	12,781 gal
PST, Anionic Polymer	0.00 mg/l	0.0 gal
Belt Press, Cationic Polymer	14.26 lbs/ton	39,676 gal
Belt Press, Lime	0 lbs/ton	0 tons
Odor Control, Sodium Hypochlorite	>575 mv	6,429 gal
Odor Control, Sodium Hydroxide	>9.0 pH	2,718 gal
Odor Control, Sulfuric Acid	<4.0 pH	38 gal
Reclaim Water Chlorine	0.0 mg/l	0 gal

## 6. September 2024 Solids Quantity

<b>Disposal Material</b>	<b>No. of Trucks</b>	<b>Weight, Tons</b>	<b>Average No. of Trucks per Day</b>
Grit/Screening Hauling	33	1,304.7	1.10
Solids Hauling	176	4,371.9	5.87

## 7. August 2024 Solids Quality

<b>Sludge Solids</b>	<b>pH</b>	<b>Raw Sludge, % Solids</b>	<b>Unstabilized Sludge, % Solids</b>	<b>Stabilized Sludge, % Solids</b>
Monthly Minimum	6.8	1.7	19.0	18.6
Monthly Maximum	7.0	5.2	26.4	28.9
Monthly Average	6.9	2.9	22.9	23.0

## 8. September 2024 Non Potable Water Usage

<b>NPW Monthly Average, gal.</b>	<b>NPW Min, gal.</b>	<b>NPW Max, gal.</b>	<b>NPW 6-month Moving Average, gal.</b>
2,370,900	1,895,000	2,886,000	2,169,692

## 5. October 2024 Chemical Dose

Location, Chemical	Dose	Consumption
PST, Ferric Chloride	8.4 mg/l	8,175 gal
PST, Anionic Polymer	0.00 mg/l	0.0 gal
Belt Press, Cationic Polymer	12.08 lbs/ton	33,077 gal
Belt Press, Lime	0 lbs/ton	0 tons
Odor Control, Sodium Hypochlorite	>575 mv	17,371 gal
Odor Control, Sodium Hydroxide	>9.0 pH	1,205 gal
Odor Control, Sulfuric Acid	<4.0 pH	46 gal
Reclaim Water Chlorine	0.0 mg/l	0 gal

## 6. October 2024 Solids Quantity

<b>Disposal Material</b>	<b>No. of Trucks</b>	<b>Weight, Tons</b>	<b>Average No. of Trucks per Day</b>
Grit/Screening Hauling	30	773.8	0.97
Solids Hauling	172	4,214.0	5.55

## 7. September 2024 Solids Quality

<b>Sludge Solids</b>	<b>pH</b>	<b>Raw Sludge, % Solids</b>	<b>Unstabilized Sludge, % Solids</b>	<b>Stabilized Sludge, % Solids</b>
Monthly Minimum	6.7	3.7	19.1	18.6
Monthly Maximum	7.0	4.1	24.9	23.4
Monthly Average	6.9	3.9	21.5	20.9

## 8. October 2024 Non Potable Water Usage

<b>NPW Monthly Average, gal.</b>	<b>NPW Min, gal.</b>	<b>NPW Max, gal.</b>	<b>NPW 6-month Moving Average, gal.</b>
2,416,226	1,953,000	3,109,000	2,265,270

## 5. November 2024 Chemical Dose

Location, Chemical	Dose	Consumption
PST, Ferric Chloride	5.7 mg/l	15,429 gal
PST, Anionic Polymer	0.00 mg/l	0.0 gal
Belt Press, Cationic Polymer	13.97 lbs/ton	45,175 gal
Belt Press, Lime	0 lbs/ton	0 tons
Odor Control, Sodium Hypochlorite	>575 mv	12,332 gal
Odor Control, Sodium Hydroxide	>9.0 pH	1,072 gal
Odor Control, Sulfuric Acid	<4.0 pH	206 gal
Reclaim Water Chlorine	0.0 mg/l	0 gal

## 6. November 2024 Solids Quantity

Disposal Material	No. of Trucks	Weight, Tons	Average No. of Trucks per Day
Grit/Screening Hauling	5	65.3	0.17
Solids Hauling	225	5,510.4	7.5

## 7. October 2024 Solids Quality

Sludge Solids	pH	Raw Sludge, % Solids	Unstabilized Sludge, % Solids	Stabilized Sludge, % Solids
Monthly Minimum	6.8	2.9	18.3	17.5
Monthly Maximum	6.9	6.1	22.8	22.4
Monthly Average	6.9	4.2	20.2	20.1

## 8. November 2024 Non Potable Water Usage

NPW Monthly Average, gal.	NPW Min, gal.	NPW Max, gal.	NPW 6-month Moving Average, gal.
2,125,767	1,542,000	2,982,000	2,354,814



## 5. December 2024 Chemical Dose

Location, Chemical	Dose	Consumption
PST, Ferric Chloride	8.9 mg/l	14,048 gal
PST, Anionic Polymer	0.00 mg/l	0.0 gal
Belt Press, Cationic Polymer	15.71 lbs/ton	38,094 gal
Belt Press, Lime	0 lbs/ton	0 tons
Odor Control, Sodium Hypochlorite	>575 mv	11,919 gal
Odor Control, Sodium Hydroxide	>9.0 pH	911 gal
Odor Control, Sulfuric Acid	<4.0 pH	84 gal
Reclaim Water Chlorine	0.0 mg/l	0 gal

## 6. December 2024 Solids Quantity

Disposal Material	No. of Trucks	Weight, Tons	Average No. of Trucks per Day
Grit/Screening Hauling	8	123.6	0.26
Solids Hauling	230	5,614.9	7.42

## 7. November 2024 Solids Quality

Sludge Solids	pH	Raw Sludge, % Solids	Unstabilized Sludge, % Solids	Stabilized Sludge, % Solids
Monthly Minimum	6.7	2.7	18.0	17.0
Monthly Maximum	6.9	4.4	21.6	24.1
Monthly Average	6.8	3.6	19.8	19.8

## 8. December Non Potable Water Usage

NPW Monthly Average, gal.	NPW Min, gal.	NPW Max, gal.	NPW 6-month Moving Average, gal.
2,065,645	1,419,000	3,124,000	2,398,667

## 5. February 2025 Chemical Dose

Location, Chemical	Dose	Consumption
PST, Ferric Chloride	16.9 mg/l	9,787 gal
PST, Anionic Polymer	0.00 mg/l	0.0 gal
Belt Press, Cationic Polymer	11.14 lbs/ton	36,351 gal
Belt Press, Lime	235.63 lbs/ton	117.27 tons
Odor Control, Sodium Hypochlorite	>575 mv	8.385 gal
Odor Control, Sodium Hydroxide	>9.0 pH	632 gal
Odor Control, Sulfuric Acid	<4.0 pH	76 gal
Reclaim Water Chlorine	0.0 mg/l	0 gal

## 6. February 2025 Solids Quantity

Disposal Material	No. of Trucks	Weight, Tons	Average No. of Trucks per Day
Grit/Screening Hauling	9	136.8	0.32
Solids Hauling	189	4,618.8	6.75

**7. January 2025 Solids Quality**

<b>Sludge Solids</b>	<b>pH</b>	<b>Raw Sludge, % Solids</b>	<b>Unstabilized Sludge, % Solids</b>	<b>Stabilized Sludge, % Solids</b>
Monthly Minimum	6.7	1.4	20.3	19.6
Monthly Maximum	7.0	5.0	27.8	27.5
Monthly Average	6.8	3.0	22.9	22.6

**8. February 2025 Non Potable Water Usage**

<b>NPW Monthly Average, gal.</b>	<b>NPW Min, gal.</b>	<b>NPW Max, gal.</b>	<b>NPW 6-month Moving Average, gal.</b>
2,285,750	1,736,000	3,547,000	2,270,332

## 5. March 2025 Chemical Dose

Location, Chemical	Dose	Consumption
PST, Ferric Chloride	20.8 mg/l	11,745 gal
PST, Anionic Polymer	0.00 mg/l	0.0 gal
Belt Press, Cationic Polymer	10.30 lbs/ton	37,392 gal
Belt Press, Lime	202.51 lbs/ton	102.91 tons
Odor Control, Sodium Hypochlorite	>575 mv	8,084 gal
Odor Control, Sodium Hydroxide	>9.0 pH	661 gal
Odor Control, Sulfuric Acid	<4.0 pH	88 gal
Reclaim Water Chlorine	0.0 mg/l	0 gal

## 6. March 2025 Solids Quantity

Disposal Material	No. of Trucks	Weight, Tons	Average No. of Trucks per Day
Grit/Screening Hauling	4	58.9	0.13
Solids Hauling	195	4,774.2	6.29

## 7. February 2025 Solids Quality

<b>Sludge Solids</b>	<b>pH</b>	<b>Raw Sludge, % Solids</b>	<b>Unstabilized Sludge, % Solids</b>	<b>Stabilized Sludge, % Solids</b>
Monthly Minimum	6.7	2.6	19.5	18.9
Monthly Maximum	7.0	5.3	31.3	31.2
Monthly Average	6.9	4.3	23.7	23.7

## 8. March 2025 Non Potable Water Usage

<b>NPW Monthly Average, gal.</b>	<b>NPW Min, gal.</b>	<b>NPW Max, gal.</b>	<b>NPW 6-month Moving Average, gal.</b>
1,940,839	680,000	2,800,000	2,215,291